

GENERAL INSTALLATION NOTES:

1. INSTALL WATER MAIN WITH 3.0 FEET OF MINIMUM COVER UNLESS OTHERWISE NOTED. DEPTH MAY INCREASE AT UTILITY AND CULVERT CROSSINGS.
2. LOCATE WIRE SHALL BE COATED (BLUE INSULATED), NO. 14 GA. SOFT DRAWN SOLID COPPER. USE WATERPROOF CONNECTORS AT ALL WIRE SPLICES.
3. NEW AND REPAIRED WATER MAINS SHALL BE DISINFECTED PER AWWA C651 PRIOR TO BEING PLACED INTO SERVICE. CONNECTION TO AN EXISTING WATER MAIN MAY ONLY BE DONE AFTER PROPER DISINFECTION, TESTING, FLUSHING AND APPROVAL BY CPU.
4. WHENEVER A PIPE IS CUT AND NOT RECONNECTED, THE CUT ENDS SHALL BE CAPPED OR PLUGGED, AS DIRECTED BY THE CPU INSPECTOR.
5. ALL WATER SERVICES, BLOW-OFF ASSEMBLIES, AIR RELEASE VALVES, FIRE HYDRANT ASSEMBLIES, VALVE BOXES AND THRUST BLOCKING SHALL BE INSTALLED PER THE STANDARD SPECIFICATIONS AND DETAILS.
6. WATER MAINS BEING INSTALLED NEAR TELEPHONE/CABLE COMMUNICATIONS SHALL HAVE A MINIMUM 12" HORIZONTAL AND 6" VERTICAL CLEARANCE.
7. WATER MAINS BEING INSTALLED NEAR UNDERGROUND ELECTRICAL LINES SHALL HAVE A MINIMUM 60" HORIZONTAL AND 6" VERTICAL CLEARANCE.
8. REQUIRED SEPARATION BETWEEN WATER LINES AND SANITARY SEWER LINES SHALL BE AS FOLLOWS:

HORIZONTAL SEPARATIONS (PARALLEL)

A MINIMUM SEPARATION OF TEN (10) FEET (MEASURED EDGE TO EDGE) BETWEEN SANITARY SEWER LINES AND WATER LINES SHALL BE MAINTAINED WHENEVER POSSIBLE. WHEN CONDITIONS PREVENT THE MINIMUM TEN (10) FOOT HORIZONTAL SEPARATION THE ENGINEER SHALL BE NOTIFIED.

VERTICAL SEPARATION (PERPENDICULAR)

WATER LINES CROSSING SANITARY SEWER LINES SHALL BE LAID ABOVE THE SEWER LINES TO PROVIDE A SEPARATION OF AT LEAST 18" BETWEEN THE INVERT OF THE WATER PIPE AND THE CROWN OF THE SANITARY SEWER PIPE. A LENGTH OF WATER PIPE SHALL BE CENTERED AT THE POINT OF CROSSING AND SHALL BE THE LONGEST STANDARD LENGTH AVAILABLE FROM THE MANUFACTURER.

9. THE CONTRACTOR SHALL USE CONSTRUCTION METHODS THAT PROTECT THE PIPE INTERIORS, FITTINGS AND VALVES AGAINST CONTAMINATION.
10. ANY PIPE, FITTINGS OR VALVES THAT CANNOT BE DISINFECTED WITH THE MAIN LINE BY CHLORINE FOR 24 HOURS SHALL HAVE THE INTERIORS SWABBED WITH A 1% HYPOCHLORITE SOLUTION BEFORE INSTALLATION.
11. CONCRETE THRUST BLOCKS SHALL BE CONSTRUCTED AT ALL TEES, BENDS, DEAD ENDS AND WHERE INDICATED ON THE PLANS.
12. ALL MJ FITTINGS SHALL BE RESTRAINED USING MJ MECHANICAL RESTRAINT FOLLOWER GLANDS APPROPRIATE FOR THE PIPE MATERIAL.
13. 6" WATER PIPE LEADING TO FIRE HYDRANTS SHALL BE DIP AND SHALL BE ONE CONTINUOUS PIECE OF PIPE. IF THE RUN IS LONGER THAN ONE PIECE OF PIPE, THEN ALL PIPE JOINTS SHALL BE MECHANICALLY RESTRAINED WITH "FIELD-LOK" GASKETS OR OTHER CPU APPROVED RESTRAINTS.

REVISED FEBRUARY 2023

FILE NAME		GENERAL INSTALLATION NOTES	
0-GI			
SHEET	1 OF 1	STANDARD DETAILS	