

## TRENCHING NOTES:

- 1. SEE CLARK COUNTY OR WSDOT UTILITY PERMIT, WHICHEVER IS APPLICABLE, FOR ADDITIONAL TRENCH BACKFILL AND SURFACING REQUIREMENTS.
- 2. NATIVE MATERIALS MAY BE SUBSTITUTED FOR IMPORTED GRANULAR MATERIAL PROVIDING IT IS PRE-APPROVED BY THE COUNTY ENGINEER OR AUTHORIZED REPRESENTATIVE.
- TRENCH EXCAVATION, BEDDING, AND BACKFILL FOR WATER MAINS SHALL BE IN ACCORDANCE WITH SECTION 7-09 OF THE MOST CURRENT STANDARD SPECIFICATIONS. BED PIPE PER SUBSECTION 7-09.3(9) OF THE STANDARD SPECIFICATIONS.
- 4. IN THE TRENCH ZONE, USE METHOD C COMPACTION PER SECTION 2-03.3(14).
- 5. PIPE BEDDING (5/8"-0; AGG. BASE) SHALL BE A MINIMUM OF 6" EACH SIDE AND TOP AND BOTTOM OF PIPE COMPACTED.

**REVISED FEBRUARY 2023** 

FILE NAME

14W

CONTROL DENSITY FILL ASPHALT CONCRETE PAVEMENT
TYPE 'D' RESTORATION

Clark Public Utilities

SHEET 1 OF 1

STANDARD DETAILS