

ALLOWABLE DIP JOINT DEFLECTION				
PIPE SIZE	ALLOWABLE DEFLECTION ANGLE	ALLOWABLE OFFSET "S"		
		PIPE L=18'	PIPE L=20'	
6"	3°	11"	12"	
8"	3°	11"	12"	
12"	3°	11"	12"	



NOTE: DEFLECTIONS IN ALIGNMENT FOR DIP SHALL BE MADE BY DEFLECTING THE PIPE JOINTS PER THE ATTACHED DEFLECTION TABLE

ALLOWABLE PVC PIPE BENDING			
PIPE SIZE	ALLOWABLE MINIMUM BENDING RADIUS	ALLOWABLE OFFSET "S"	
6"	200'	12"	
8"	250'	9.5"	
12"	350'	7"	

NO BENDING OF PVC PIPE ALLOWED FOR PIPE LARGER THAN 12" DIAMETER



NOTE: DEFLECTIONS IN ALIGNMENT FOR PVC PIPE SHALL BE MADE BY BENDING THE PIPE AND NOT DEFLECTING PIPE JOINTS

REVISED FEBRUARY 2023

27W

DUCTILE PIPE DEFLECTION & PVC PIPE BEND DETAIL

Clark Public Utilities

SHEET 1 OF 1

FILE NAME

STANDARD DETAILS