

REVISION JUNE 18, 2024									
NEW ITEMS & CHANGES ARE ITALICIZED AND BOLD*									
CLARK PUBLIC UTILITIES - APPROVED MATERIAL LIST									
APPROVED MANUFACTURERS/PART NUMBER(S)									
CPU STOCK NO.	DESCRIPTION	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE
2862	ARM VAULT, CABLE RACK, 14"	MACLEAN J5134A	1,2,5,11	CONDUX 08380900	1,2,3				
2863	ARM VAULT, CABLE RACK, 18"	CONDUX 08381000	1,2,3						
2460	BARRIER, TRANSFORMER, 16" HILLSIDE	PROGLASS HB164648	1,2,5,11,17						
2461	BARRIER, TRANSFORMER, 32" HILLSIDE	PROGLASS HB324648	1,2,5,11,17						
1389	BOLT, HEXHEAD, W/BELLEVILLE & FLAT WASHERS ASSEMBLED: (1) 1/2" - 13X2" HEXHEAD SS BOLT 18-8; (2) 1/2" 50 LB SS BELLEVILLE WASHERS; (2) 1/2" 18-8 FLAT WASHERS; (1) 1/2" - 13 SILICONE BRONZE HEX NUT	ASSEMBLED COMPONENTS: WFL88.050 HCS88.050C0200 WBESS.050 NFHSB.050C	14						
131	BOLT, MACH 1/2 X 1 1/2 NC GRD 5, 304 STAINLESS STEEL	HCS588.050C0150	14	50C150HCSS	9				
132	BOLT, MACH 1/2 X 2 NC GRD 5, 304 STAINLESS STEEL	HCS588.050C0200	14	50C200HCSS	9				
194	BOX, JCT., 1 PH, FIBERGLASS WITH LBC4, #2 GROUND BAR INSTALLED, MUNSELL GREEN	PDI CJP-10-33-L2-MG-2415-GB2-1333-R	1,2,5						
2047	BOX, JCT., 3 PH, FIBERGLASS W/LBC4'S, #2 GROUND BAR INSTALLED, 49" HI., MUNSELL GREEN	PDI CJP-30-50-L2-MG-2415-GB2-1137-R	1,2,5						
2940	BOX, JCT., 1 PH, FIBERGLASS W/LBC5, 200A BUSHING INSERTS, #2 GROUND BAR INSTALLED, MUNSELL GREEN	PDI CJP-15-49-L2-MG-2515-GB2-4404-R	1,2,5						
2941	BOX, JCT., 3 PH, FIBERGLASS W/LBC5'S, 200A BUSHING INSERTS, #2 GROUND BAR INSTALLED, MUNSELL GREEN	PDI CJP-40-50-L2-MG-2515-GB2-4403-R	1,2,5						
2556	BOX, JCT, UG, COMPOSITE, LIGHT DUTY (10K#) W/ COVER, 17"X30"X18" W/ PENTA BOLTS	ARMORCAST A6001640AX18	2	HUBBELL A12173018A017	2	QUAZITE PG1730Z540-84	2		
2608	BOX, JCT., U.G. COMPOSITE, HVY DUTY (20K#) W/COVER, 24"X36"X18" DEEP W/PENTA BOLT(S)	ARMORCAST A6001974HDAPCX18-1	2,5	QUAZITE PG2436BA18	2				
1828	BRACKET, MOUNTING, VAULT, 24"	KORTICK K5114	1	CONDUX 08380100	1,2,3				
2860	BRACKET, MOUNTING, VAULT, 15"	MACLEAN J5124	1,2,5,11	CONDUX 08380000	1,2,3				
2861	BRACKET, MOUNTING, VAULT, 30"	MACLEAN J5126	1,2,5,11	CONDUX 08380200	1,2,3				
2434	BRACKET, TRANSFORMER DEFERRAL (FOR STK# 2433 BOXPAD)	NORDIC TDB-2	1,2,3						
237	BUSHING, FEED-THRU 8.3/14.4kv, 200AMP	COOPER LFI-215	2,5,11,16,18						
252	BUSHING, STANDOFF INSUL. 200 AMP	ELASTIMOLD 161-SOP	1,2,18	COOPER ISB215	2,5,11,16,18	HUBBELL 215SB	2,5		
2144	CAP, CABLE END, UG PRIMARY 1/0 & 2	3M EG-2	1,2,3,5,11,16,18						
2239	CAP, CABLE, STREETLITE, RED 40"	RADAR ENG. 610	1,2,3,6						
265	CAP, PROTECTIVE INSUL. 200 AMP 15kv	COOPER LPC215	2,5,11,16,18	ELASTIMOLD 160 DRG	1,2,18	HUBBELL 215ICI	2		
272	CEMENT, PVC	WELDON 717 GREY 1PT	1,2,3,5	OATEY 31095	1,2	CARLON VC9923	1,2,3,11,16,18		
281	CLAMP, GROUND ROD 5/8" BRZE SMALL	ERITECH HDC-58	1,2,5,11	BLACKBURN G-5	1,2,16,18	MACLEAN J8492	1,2,5,11	WILCOR WAG5/8	1,2
		PORCELAIN PROD. 8058SP	1,2,3	GALVAN SRC	1				
1553	CONDUCTOR, BSDC, #2 SOLID, 1 COND.		1,2,5,11,16,18						
376	CONDUCTOR, BSDC, #4 SOLID, 1 COND.		1,2,5,11,16,18						
350	CONDUCTOR, UG AL 8 2C 600V BARD	"TWISTED" BARD	1,2,5,11,16,18						
2387	CONDUIT, HDPE, 1", SDR 13.5, SMOOTHWALL, RED, W/ PULLING STRING	ARNCO	1,2,3,11	INTEGRAL	2	CASCADE POLY	3,4	DURALINE	1,2
2208	CONDUIT, P&C FLEX, 2", GRAY	CARLON #11811-250	1,2,3,11,16,18						
2575	CONDUIT, P&C FLEX, 3", GRAY	CARLON #11813-250	1,2,3,11,16,18						
2190	CONDUIT, PVC SCH 40, 2" X 20', CHAMFERED 45 DEG.	BELL END (UL LISTED)	1,2,3,5,10,11,16,18						
2209	CONDUIT, PVC SCH 40, 4" X 20', CHAMFERED 45 DEG.	BELL END (UL LISTED)	1,2,3,5,10,11,16,18						
2318	CONNECTOR, Z-BAR, 1" STUD, AL/CU, 6-POSITION, #2-500MCM, W/ STREETLIGHT	UTILCO PSS6-500JSL-1"	1,2,5,11,18	HOMAC Z-4025 -1"-SL	1,2	CMC ZQ6-500SL	1,2		
2265	CONNECTOR, Z-BAR, 5/8" STUD, AL/CU, 6-POSITION, #2-500MCM, W/STREETLIGHT	CMC ZQ6-500ASL	1,2	UTILCO PSS6-500JSL-L5/8	1,2,5,11	HOMAC Z-2045-58-SL or Z6559	1,2		
416	CONNECTOR, H-TAP, AL/CU, RUN #6-#2 STR - TAP #14-#8 STR	BLACKBURN #WR9	1,2,3,16,18						
456	CONNECTOR, CU CRIMPET, 2/0 - #2	BURNDY YC26C2	2,3,16,18						
457	CONNECTOR, CU CRIMPET, 2/0 - 2/0	BURNDY YC26C26	2,3,16,18	PENN UNION CCT 2020	1,2,5,11				
455	CONNECTOR, CU CRIMPET, 2/2 - 2/2	BURNDY YC2C2	2,3,16,18	PENN UNION CCT 22	1,2,5,11	HOMAC CC 22	1,2	UTILCO UTL-7	1,2,11
454	CONNECTOR, CU CRIMPET, 2/2 - 4/4	BURNDY YC2C4	2,3,16,18	PENN UNION CCT 24	1,2,5,11	HOMAC CC 24	1,2	UTILCO UTL-6	1,2,11
528	CONNECTOR, PED 4-350, AL/CU 6 TO 350	UTILCO PED 4-350	1,2,5,11	HOMAC ABC 4350	1,2	CMC NA350-4	1,2	ELASTIMOLD PSP4359	1,2,18
531	CONNECTOR, PED 6-350, AL/CU 6 TO 350	UTILCO PED 6-350	1,2,5,11	HOMAC ABC 6350	1,2	ALCON PD6-350	1		
2312	CONNECTOR, PET 6-500, AL/CU 2 TO 500	CMC L6D8-500	1,2,5						
2129	CONNECTOR, PET #2-750, AL/CU, 6-POSITION	CMC L6D10-750I	1,2,5						
2598	CONNECTOR, PET #8-1000MCM, SET SCREWS, 8-POS POSITION, #12 SOLID TO 500MCM AL/CU	CMC L8D141000I	1,2,5	HOMAC ABT81000	1,2				
2264	COUPLING, 2", PE to PVC, MECHANICAL	RACEWAYS TECH S80-2PE-PVC	1,2,3,5,11,18						
2844	COUPLING, 4", PE to PVC, MECHANICAL	RACEWAYS TECH S80-4PE-PVC	1,2,3,5,11,18						
553	COUPLING, CONDUIT, 2 IN PVC SXS DEEP SOCKET	RIDGELINE 40SWC20	1,2,3,11,16,18						
557	COUPLING, CONDUIT, 3 IN PVC SXS DEEP SOCKET	RIDGELINE 40SWC30	1,2,3,11,16,18	ATKORE / HERITAGE 40SWC30	3,11,16,18				

REVISION JUNE 18, 2024										
NEW ITEMS & CHANGES ARE ITALICIZED AND BOLD*										
CLARK PUBLIC UTILITIES - APPROVED MATERIAL LIST										
APPROVED MANUFACTURERS/PART NUMBER(S)										
CPU STOCK NO.	DESCRIPTION	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE
2316	COUPLING, REDUCER, PVC 3" TO 2", SCH 40	BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
2336	COUPLING, REDUCER, PVC 4" TO 2", SCH 40	BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
2266	COVER, CONNECTOR, Z-BAR, 6-POSITION	CMC ZLC-3	1,2	UTILCO PSS B-2	1,2,5,11	HOMAC EZ 5912-3	1,2	BLACKBURN TZB6559D58C	1,2,16,18	
573	COVER, CONNECTOR, 4-350 PVC (FOR 528)	CMC NC6-350	1,2	HOMAC BB-13	1,2	ALCON CVC	1,2			
574	COVER, CONNECTOR, 6-500 PVC (FOR 531)	CMC NC6-500	1,2							
2176	COVER, CONNECTOR, 6-750 PVC (FOR 2129)	CMC LDC-2	1,2,5	HOMAC, SB2163-12	1,2	POLARIS 50750HK12	2,5			
2182	COVER, CONNECTOR, 8-750 FOR PET	HOMAC SB2163-3	1,2	POLARIS 50750128	2,5					
2435	COVER, FOR GROUND SLEEVE (2433)	PROGLASS LTX4238	1,11,17							
2391	ELBOW CABLE SEALING 1/0 URD, 175 MIL INSUL	3M 8452	1,2,3,5,11,16,18							
2391B	ELBOW CABLE SEALING 1/0 URD, 175 MIL INSUL	RAYCHEM RVS-13-SK	1,2,11,16,18							
1312	ELBOW LB 1/0, 200A, 175/220 MIL INSUL	EATON #LEJ215AB06TY	2,5,11,16,18	ABB (Elastimold) #162LRJS-B5240	1,2,18	HUBBELL 215LEJ45T	1,2			
N/A	<b>ELBOW LB 1/0, 200A, 175/220 MIL INSUL W/O JACKET SEAL - **MUST BE PURCHASED W/ STK# 2391 OR STK# 2391B** APPROVED FOR AN "AS NEEDED" SUBSTITUTION FOR STK#1312 IF UNAVAILABLE.</b>	<b>EATON #LEJ215AB06TY **Must purchase with Stk# 2391 or 2391B</b>	2,5,11,16,18	<b>ABB (Elastimold) #162LR-B5240-S **Cold Shrink is included</b>	1,2,18	<b>HUBBELL 215LE45TJ **Must purchase with Stk# 2391 or 2391B</b>	1,2			
1531	ELBOW, PVC, 2", 90 DEG, 36" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
1532	ELBOW, PVC, 2", 90 DEG, 24" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
3015	ELBOW, PVC, 2", 22 1/2 DEG, 36" RADIUS, SCH 40,	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
3016	ELBOW, PVC, 2", 45 DEG, 36" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
2574	ELBOW, PVC, 3", 90 DEG, 24" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
1655	ELBOW, PVC, 3", 45 DEG, 24" RADIUS, SCH 40,	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
1535	ELBOW, PVC, 4", 90 DEG, 36" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
1536	ELBOW, PVC, 4", 90 DEG, 24" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
2140	ELBOW, PVC, 4", 11 DEG, 36" RADIUS, SCH 40	STRAIGHT ENDS (UL LISTED)	1,2,3,5,10,11,16,18							
3017	ELBOW, PVC, 4", 22 1/2 DEG, 36" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
3018	ELBOW, PVC, 4", 45 DEG, 36" RADIUS, SCH 40	(1) BELL END (UL LISTED)	1,2,3,5,10,11,16,18							
1821	ENCLOSURE, CABLE LOOP, FIBERGLASS 30"X30"X8" W/5" FLNGE	NORDIC LP-77	1,2,3,5	PROGLASS LE29830	1,11,17					
2213	ENCLOSURE, ELBOW (EE), 3PH, FIBERGLASS 72"X49"X44", MUNSELL GREEN	CDR SPM-540-53DF3MG	1,2	PDI CJP-30-50-L2-MG	1,2,5					
2388	HOLDER, FUSE, STREET LIGHT	HOMAC FLOOD SEAL SLK-M	1,2							
2694	INDICATOR, FAULT, 400A TEST POINT, VOLTAGE RESET, 1 PH, UG	SCHWEITZER TPR#BH6G	1,2,5,11							
1608	LUBRICANT, CABLE PULLING, LIQUID, TYPE PJ, (1 GAL)	POLYWATER PJ-128	1,2,3,5,11,18							
1609	LUBRICANT, CABLE PULLING, LIQUID, TYPE PJ, (5 GAL)	POLYWATER PJ-640	1,2,3,5,11,18							
2789	LUBRICANT, FRONT END BAGS, 1 QUART FOR 2" & 3" CONDUIT	POLYWATER J-27	1,2,3,5,11,18							
2790	LUBRICANT, FRONT END BAGS, 1/2 GAL FOR 4" & 6" CONDUIT	POLYWATER J-55	1,2,3,5,11,18							
343	LUBRICANT, SILICONE	NOVAGARD G623	1,2							
842	LUG, TRANSFORMER, 8 SOL-2/0 STR, 4 WAY	COOPER 0701528A05	2,16,18	PENN UNION HGSE-020	1,2,5,11	BLACKBURN TTC2	1,2,16,18	ANDERSON GTC534A	2	
2210	MARKER, UNDERGROUND, DISC, FULL RANGE	3M 1251	1,2,3,5,11,16,18							
901	MODULE, LBC4 UG W/O BRACKET	ELASTIMOLD 164J4-5 W/O BRKT	1,2,5,18	HUBBELL 215J4U	1,2	COOPER LJ215C4U	2,5,11,16,18			
920	NUT, SPRING LOADED GALV 1/2 IN (UNI-STRUT)	B-LINE N225-YZN	1,2,3,18	KINDORF B911-1/2	1,2,18	SUPERSTRUT A-100-1/2	1,2,18			
2170	PAD, TRANS, CONCRETE, 3PH 75-1500 KVA UTP4	USE CPU STANDARD UTP4	5,7,8,11							
929	PAD, TRANSFORMER, 42" X 42", 1PH, 25-75kVA	ARMORCAST A6001879-1227	2,5	QUAZITE PH42421227507	2,11	OLDCASTLE PBP424203-1227U	3,5,8	JENSEN PRECAST 2000075620-HPC4242	1,2	
930	PAD, TRANSFORMER, 48" X 46", 1PH, 100kVA ONLY	QUAZITE PH48461826G3S	2,11,16	ARMORCAST A6001998	2,5					
N/A	PAD, TRANSFORMER, 112" X 84", UTP5	OLDCASTLE 0370133	3,5,8							
2562	PEDESTAL, ABOVE GRD W/ CONN'S & COVERS, MUNSELL GRN	SMAC PLASTICS PF300C1G-MG188	1,2	CMC PF300-LI350-6IUH	1,2	NORDIC PSPF-101538-MG-L6350A-CCPUD	1,2,5			
2697	PLUG, PLASTIC, BLACK FOR 2" PVC CONDUIT	EAGLE 61800200	1,11	RIDGELINE UTP20	1,2					
2698	PLUG, PLASTIC, BLACK FOR 4" PVC CONDUIT	EAGLE 61800400	1,11	RIDGELINE UTP40	1,2					
1124	ROD, GRD 5/8in X 8 ft, CU CLAD	GALVAN 6258	1,5	ERITECH 615880	1,2,5,11					
1278	TAG, CABLE UG PLASTIC, YELLOW (METERED TEMP ONLY)	RADAR ENG. 609	6							
2592	TAPE, PULLING 3/4" WIDE, 2500#, 5000 FT.	HERCULINE HL-P2500W-5K	2,3,11,19,20	DURALINE 20000080	1,2					
2592A	TAPE, PULLING 3/4" WIDE, 2500#, 1000 FT.	HERCULINE HL-P2500W-1K	2,3,11,19,20	DURALINE 20000073	1,2					
2433	BOXPAD, 1PH, TRANSFORMER, FIBERGLASS, 42"X38"X20"	PROGLASS TX423820	1,11,17							
2722	VAULT, 575LA, UFER GROUND, NON-SLIP LID	OLDCASTLE 575LA W/ GROUND INSERTS AND 57T-2-332NS COVER	3,5,8							
2957	VALUT, W/ LID, 612 3LA, UFER GROUND	OLDCASTLE 612 3 LA CLARK	3,5,8							
N/A	VALUT, 6' X 4' X 3'-6"	OLDCASTLE 644LA	3,5,8							
1415	WASHER, 2"X3", 3/16" X 9/16" SLOTTED HOLE	WILLAMETTE MFG #9/16-GW	2,11							
1245	WRAP, TIE PLASTIC 8"	T&B TY5272MX	1,11							
1245	WRAP, TIE PLASTIC 13"	T&B TY527MX	1,11							

REVISION JUNE 18, 2024											
NEW ITEMS & CHANGES ARE ITALICIZED AND BOLD*		<b>CLARK PUBLIC UTILITIES - APPROVED MATERIAL LIST</b>									
CPU STOCK NO.	DESCRIPTION	APPROVED MANUFACTURERS/PART NUMBER(S)	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE	SUPPLIER CODE
<b>UNDERGROUND TAGGING SYSTEM</b>											
2588	HOLDER, IDENTIFICATION TAGS, 4 POSITION	Tech Products PH105	1,2,5,11								
2589	HOLDER, IDENTIFICATION TAGS, 8 POSITION	Tech Products PH108	1,2,5,11								
2977	HOLDER, IDENTIFICATION TAGS, 10 POSITION	Tech Products PH110	1,2,5,11								
VARIOUS	TAG, CHARACTER	Tech Products ELHKYX,XXX	1,2,5,11								
2591	BOX, STEEL STORAGE FOR TAGS	Tech Products SB-1	1,2,5,11								
<b>PRIMARY AND SECONDARY CABLE</b>											
<b>SEE CABLE SPECIFICATIONS*</b>											
2390	CABLE, 15KV UG AL 1/0 EPR 175M INS.W/050 JKT	KERITE	1,2	OKONITE	2	CME		1			
<b>ONLY MANUFACTURERS LISTED ARE APPROVED AS OF 8/2010</b>											
361	COND, UG AL 4/0 3C 600v "SWEETBRIAR" UL Labeled	SUPPLIERS: 1,2,5,11,16,18 (SEE CABLE SPECIFICATIONS)*									
362	COND, UG AL 350 3C 600v "WESLEYAN" UL Labeled	SUPPLIERS: 1,2,5,11,16,18 (SEE CABLE SPECIFICATIONS)*									
2922	COND, UG AL 4/0 4C 600V, "WAKE FOREST" UL Labeled	SUPPLIERS: 1,2,5,11,16,18 (SEE CABLE SPECIFICATIONS)*									
2923	COND, UG AL 350 4C 600V, "SLIPPERY ROCK" UL Labeled	SUPPLIERS: 1,2,5,11,16,18 (SEE CABLE SPECIFICATIONS)*									
<b>1 PHASE AND 3 PHASE PAD TRANSFORMERS</b>											
<b>SEE TRANSFORMER SPECIFICATIONS*</b>											
<b>1 PHASE PAD TRANSFORMERS</b>											
<b>MAX. NO LOAD LOSS</b>											
<b>MAXIMUM LOAD LOSS</b>											
<b>MAX. FAULT CURRENT</b>											
1317	25 KVA, 240/120, 12470 GRD Y 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,18		80 WATTS		245 WATTS		10,000 AMPS			
1318	50 KVA, 240/120, 12470 GRD Y 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,18		115 WATTS		495 WATTS		10,000 AMPS			
1320	75 KVA, 240/120, 12470 GRD Y 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,18		174 WATTS		600 WATTS		10,000 AMPS			
1322	100 KVA, 240/120, 12470 GRD Y 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,18		149 WATTS		1045 WATTS		14,000 AMPS			
<b>3 PHASE PAD TRANSFORMERS</b>											
<b>MAX. NO LOAD LOSS</b>											
<b>MAXIMUM LOAD LOSS</b>											
<b>MAX. FAULT CURRENT</b>											
1328	75KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		255 WATTS		665 WATTS		10,000 AMPS			
1329	150KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		420 WATTS		1200 WATTS		22,000 AMPS			
1331	300KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		645 WATTS		2025 WATTS		42,000 AMPS			
1332	500KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		870 WATTS		3395 WATTS		65,000 AMPS			
1333	750KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		950 WATTS		6100 WATTS		65,000 AMPS			
1334	1000KVA, 208Y/120, 12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		1300 WATTS		6995 WATTS		85,000 AMPS			
1337	75 KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		260 WATTS		670 WATTS		14,000 AMPS			
1338	150KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		420 WATTS		940 WATTS		14,000 AMPS			
1340	300KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		720 WATTS		1890 WATTS		25,000 AMPS			
1341	500KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		865 WATTS		2410 WATTS		30,000 AMPS			
1342	750KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		975 WATTS		4545 WATTS		30,000 AMPS			
1343	1000KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		1100 WATTS		6300 WATTS		50,000 AMPS			
1344	1500KVA, 480/277,12470 GRDY 7200, 4 TAPS BELOW	SUPPLIERS: 1,2,5,11,12,13,15, 18		2000 WATTS		8590 WATTS		50,000 AMPS			
<b>SUPPLIER KEY:</b>											
1. GENERAL PACIFIC INC, 22414 NE Townsend Way, Fairview, OR 97024 503-907-2900											
2. WESCO/ANIXTER, 19545 NE Riverside Parkway, Portland, OR 97230 503-943-5100											
3. <b>D.S. Associates, 11406 NE Rosewood Ave, Suite E, Vancouver WA 98662 503-640-8188</b>											
4. CASCADE POLY PIPE & CONDUIT, 2257 Progress Way, Woodburn, OR 97071 971-444-0273											
5. ALPHA NW, 2500 E 5th St, Vancouver, WA 360-209-7800											
6. RADAR ENGINEERS, 9535 NE Cofax St, Portland, OR 97220 503-256-3417											
7. BATTLE GROUND ROCKERY (TAPANI MATERIALS), 915 E. Main St, Battle Ground, WA 98604 360-666-6718											
8. OLDCASTLE PRECAST, 28499 SW Boberg Rd, Wilsonville, OR 97070 503-682-2844											
9. VANCOUVER BOLT, 805 W 11th St, Vancouver, WA 98660 360-699-4406											
10. RACEWAY TECH. & MFG, INC, 1427 E. 26th St, Tacoma WA 98421 253-274-8477											
11. PLATT ELECTRIC, 4117B NE Minnehaha, Vancouver, WA 98661 360-699-4833											
12. CARLSON SALES, 16506 NE 182nd Ave, Brush Prairie, WA 98606, 360-573-8203											
13. MCKAIG-EVERGREEN, PO BOX 681, BOTHELL, WA 98041, 206-485-9700											
14. MT HOOD FASTENER, 1009 SE Lincoln, Portland, OR 97214, 503-233-3330											
15. MADDDOX INDUSTRIAL TRANSFORMER, 1601 SE Commerce Ave., Battle Ground, WA 98604 360-209-8088											
16. REXEL, 9730 SW Hillman Ct, Bldg 6, Suite 600, Wilsonville, OR 97070, 503-691-7950											
17. PROGLASS, sales@proglassinc.com 253-884-4008											
18. NORTH COAST ELECTRIC, 5900 NE 88th St #209, Vancouver, WA 98665 360-573-8220											
19. PACIFIC STRAPPING, sales@pacstrap.com 206-262-9800											
20. VAN PORT RIGGING, 6000 NE 88th St, Bldg C, Suite 106, Vancouver, WA 98665 360-574-1300											
* <b>ALL CABLE AND TRANSFORMERS MUST MEET TECHNICAL SPECIFICATIONS AND LOSS MAXIMUM LIMITS (TRANSFORMERS) OF CLARK PUBLIC UTILITIES.</b>											
<b>CONTACT CARLY BECK, STANDARDS ENGINEER, (360) 992-8830, FOR COPIES OF SPECIFICATIONS. MATERIALS OTHER THAN THOSE LISTED, OR UN-APPROVED CABLES</b>											
<b>AND NON-CONFORMING TRANSFORMERS ARE SUBJECT TO REJECTION AND ENERGIZATION OF FACILITIES WILL NOT BE PERFORMED.</b>											
<b>THE CURRENT TRANSFORMER SPECIFICATIONS ARE AVAILABLE ON OUR WEBSITE AT WWW.CLARKPUBLICUTILITIES.COM.</b>											

<b>REVISION JUNE 18, 2024</b>									
<i>NEW ITEMS &amp; CHANGES ARE ITALICIZED AND BOLD*</i>		<b>CLARK PUBLIC UTILITIES - APPROVED MATERIAL LIST</b>							
<b>CPU STOCK NO.</b>	<b>DESCRIPTION</b>	<b>APPROVED MANUFACTURERS/PART NUMBER(S)</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>	<b>SUPPLIER CODE</b>
<b>TOOLS AND EQUIPMENT</b>									
	1/0 PRIMARY STRIPPER TOOL, RIPLEY "BANANA PEELER" BP1A		WESCO, 503-221-5664, Alpha NW 360-209-7800						
	SECONDARY CABLE STRIPPER, RIPLEY UTILITY TOOL 36000-520		WESCO, 503-221-5664, Alpha NW 360-209-7800						
	BURNDY MD6 TOOL & "C"(CRIMPET) AND "BG" (1/0 SLEEVE) DIES		WAGNER SMITH 503-692-0979, ANIXTER 503-943-5100, WESCO 503-221-5664, ALPHA NW 360-209-7800						
	PENTA BOLT SOCKET WRENCH		GENERAL TOOL, 800-783-3411, Alpha NW 360-209-7800						
<b>*CHANGE LOG:</b>									
<i>Added Vendor # 3 - D.S. Associates for conduit related items. Updated cold shrink requirements for substitute elbow when Stk# 1312 is unavailable.</i>									