



NOTES:

1. PLACE VENT AND AIR RELEASE UNIT ASSEMBLY OUTSIDE OF HARD SURFACED AREA IN R.O.W. OR 15' EASEMENT DEDICATED TO THE CITY OF VANCOUVER
2. MANHOLE COVER SHALL MEET SANITARY SEWER STANDARD DETAIL S-2.2 STANDARD LID OR APPROVED EQUAL.
3. ADD 4'x4'x4" CONCRETE PAD IF THE AIR RELEASE IS INSTALLED IN A "SOFTSCAPE" AREA.

REVISED JANUARY 2025

FILE NAME		COMBINATION AIR RELEASE VALVE	
9W			
SHEET	1 OF 1	STANDARD DETAILS	