

EXISTING WATER SERVICES:

THE CONTRACTOR SHALL TRANSFER, MOVE AND/OR ABANDON EXISTING WATER SERVICES AS DIRECTED BY THE CLARK PUBLIC UTILITIES INSPECTOR.

1. EXISTING WATER SERVICES TO BE ABANDONED SHALL BE **ABANDONED AT** THE CORP, A 12" SECTION TO BE REMOVED AND BOTH ENDS TO BE CAPPED. STOP AT THE WATER MAIN AND THE CORP STOP SHALL BE CLOSED. THE METER BOX SHALL BE REMOVED AND THE WATER SERVICE LINE CAN BE ABANDONED IN PLACE. THE EXISTING METER SHALL BE **REMOVED BY** CLARK PUBLIC UTILITIES WATER DEPT. ROAD REPAIR SHALL BE AS REQUIRED BY THE CLARK COUNTY RIGHT OF WAY PERMIT REQUIREMENTS.
2. WHEN AN EXISTING WATER SERVICE IS TO BE MOVED, THE CONTRACTOR SHALL EXPOSE A PORTION OF THE EXISTING WATER SERVICE SO THAT THE CLARK PUBLIC UTILITIES INSPECTOR CAN EVALUATE THE MATERIAL SIZE AND CONDITION OF THE EXISTING WATER SERVICE LINE.

THE INSPECTOR WILL DETERMINE WHETHER THE WATER SERVICE LINE CAN BE EXTENDED OR SHORTENED. IF THE INSPECTOR DETERMINES THE EXISTING WATER SERVICE LINE IS SUBSTANDARD, THEN A NEW POLYETHYLENE (PE) SERVICE LINE SHALL BE INSTALLED FROM THE WATER MAIN (MINIMUM SIZE 1" DIA).

ALL EXISTING WATER SERVICE LINES THAT ARE LESS THAN 1" DIAMETER SHALL BE CONSIDERED SUBSTANDARD AND SHALL BE REPLACED WITH A NEW WATER SERVICE LINE PER CLARK PUBLIC UTILITIES STANDARDS.

MAIN LINE PIPE MATERIAL:

UNLESS OTHERWISE STATED ON THE PLAN, ALL MAIN LINE PIPE SHALL BE EITHER DUCTILE IRON PIPE (DIP), MANUFACTURED IN THE USA, OR POLYVINYL CHLORIDE PIPE (PVC). ALL PIPE SHALL BE SUITABLE FOR POTABLE WATER SERVICE IN ACCORDANCE WITH ANSI/NSF 61 STANDARDS.

- A. DUCTILE IRON PIPE SHALL CONFORM TO ANSI A21.51 OR AWWA C151. USE PUSH-ON JOINTS EXCEPT WHERE OTHER JOINT TYPES ARE NOTED ON THE CONTRACT DRAWINGS. UNLESS SPECIFICALLY NOTED ON THE CONTRACT DRAWINGS, 4"-12" PIPE SHALL BE THICKNESS CLASS 52 AND PIPE SIZES GREATER THAN 12" DIAMETER SHALL BE PRESSURE CLASS **350**.
- B. POLYVINYL CHLORIDE (PVC) PRESSURE PIPE (4"-**12"**). USE UN-PLASTICIZED PVC PLASTIC PIPE WITH INTEGRAL BELL AND SPIGOT JOINTS. USE PUSH-ON JOINTS EXCEPT WHERE OTHER JOINT TYPES ARE NOTED ON THE CONTRACT DRAWINGS. PIPE SHALL MEET THE REQUIREMENTS OF DR 18, UNLESS OTHERWISE NOTED ON THE DRAWING. UNLESS SPECIFICALLY NOTED ON THE CONTRACT DRAWINGS, 4"-12" PIPE SHALL MEET THE REQUIREMENTS OF AWWA C900.
- C. WHEN HIGH-DENSITY POLYETHYLENE PIPE (HDPE) IS REQUIRED OR ALLOWED IT SHALL BE BLACK WITH A MINIMUM OF TWO EQUALLY SPACED BLUE COLORED STRIPES EXTRUDED INTO THE OUTER SHELL IN CONFORMANCE WITH THE UNIFORM COLOR CODE (UCC). UNLESS OTHERWISE NOTED ON THE DRAWINGS, PIPE SHALL BE IRON PIPE SIZE (IPS) AND HAVE A WALL-THICKNESS DIMENSION RATIO (DR) OF 9. LARGE DIAMETER PIPE (4"-**12"**) PIPE SHALL CONFORM TO ANSI/AWWA C906.

REVISED JANUARY **2026**

FILE NAME		MAIN LINE PIPE MATERIAL & EXISTING WATER SERVICE NOTES	<div>Clark Public Utilities</div> 
0-PM			
SHEET	1 OF 1	STANDARD DETAILS	