



**TRENCHING NOTES:**

1. SEE CLARK COUNTY OR WSDOT UTILITY PERMIT, WHICHEVER IS APPLICABLE, FOR ADDITIONAL TRENCH BACKFILL AND SURFACING REQUIREMENTS.
2. TRENCH EXCAVATION, BEDDING, AND BACKFILL FOR WATER MAINS SHALL BE IN ACCORDANCE WITH SECTION 7-09 OF THE MOST CURRENT STANDARD SPECIFICATIONS. BED PIPE PER SUBSECTION 7-09.3(9) OF THE STANDARD SPECIFICATIONS.
3. IN THE TRENCH ZONE, USE METHOD C COMPACTION PER SECTION 3-03.3(14)C.
4. PIPE BEDDING SHALL BE A MINIMUM OF 12" EACH SIDE OF PIPE COMPACTED.

REVISED JANUARY 2026

|           |        |   |   |
|-----------|--------|---|---|
| FILE NAME |        | NON-PAVED ROAD SURFACES<br>TRENCH RESTORATION | <div>Clark<br/>Public<br/>Utilities</div>  |
| 10W       |        |   |   |
| SHEET     | 1 OF 1 | STANDARD DETAILS                              |   |